



#### NOTES:

1. For use when preapproved by City Engineer.
2. Concrete to have compressive strength of 4,000 psi at 28 days.
3. Drainage weephole shall be 3-inch diameter I.D. plastic pipe with coupling and beveled outlet end to match face of curb.



City Of Beaverton

#### ENGINEERING DEPARTMENT

CITY ENGINEER  
Terry Waldele, P.E.

#### MOUNTABLE CURB AND GUTTER AT VAULT DRAIN WEEPHOLE

DATE  
6 - 10 - 04

DRAWN BY  
JCH - CPD

DRAWING NO.  
202